

Make fire prevention a high priority for your business. Always be on the look-out for fire hazards and make sure you have the proper fire safety equipment.

Exits

- Exit corridors and aisles remain unobstructed, free of any material or matter at all times
- Exit doors are able to be opened from inside without a key, special knowledge, or effort
- Main entry door, ONLY, may have deadbolt lock but is unlocked during business hours, without fail
- Exit signs in place to clearly indicate exit path, minimum 6-inch letters with 3/4-inch stroke
- Exit signs are illuminated when building is occupied

Fire Extinguishers and Fire protection Systems

- Fire extinguishers serviced annually by State Fire Marshal-licensed company as well as if discharged or if tampered with
- Extinguishers have minimum rating of 2A:10B:C and are located at an exit or on an exit path every 75 feet of travel or as otherwise required by the Fire Department
- Extinguishers mounted 3-1/2 to 5 feet above floor
- Fire Protection systems shall be tagged quarterly and annually by State Fire Marshal-licensed company

Electrical

- No extension cords or multi-plug adapters in use
- No electrical cords extending through walls, ceilings, floors, under doors, or floor covering
- No damaged electrical cords, plugs, or outlets
- 30-inch minimum clearance maintained around circuit panel

General Fire Safety

- Combustible storage maintained at least 24 inches below ceiling (18 inches if sprinklered)
- No combustibles stored in furnace or electrical rooms or below stairs
- Clearance maintained between heat-producing equipment and combustibles
- Storage maintained in neat and orderly manner to minimize fire spread and facilitate control
- Dumpsters are a minimum of 5 feet from combustibles; covers kept closed

- Compressed gas cylinders are properly secured and contents clearly labeled.

Fire-Resistive Barriers

- Fire doors and fire dampers maintained to be fully operational
- Fire-resistive walls and ceilings maintained without holes, breaks, or missing panels

Flammable Liquids

- Orlando Fire Dept. restrictions regarding flammable liquids continually observed

Hazardous Materials

- Orlando Fire Dept. renew annually Hazardous Materials Inventory Statement with quantity stored and quantity in regular use

Fire Hydrants (Private owned)

- Fire hydrants serviced, tagged and painted annually by licensed company. Send report to the Orlando Fire Dept. 78 W. Central Blvd., Orlando, FL 32801 attention Hydrant Coordinator.