

# PRIVATE SANITARY SEWER LIFT STATION REQUIREMENTS

Pursuant to The City of Orlando Code, Chapter 30, Section.02, Private Wastewater Collection System Connected to Publicly-Owned Treatment Works shall comply with the following:

- 1) Discharger of private wastewater collection system must provide a copy of the contract with a reputable person or firm experienced in the operations, maintenance, and repairs of lift stations for review prior to committing to contract for service. The contractor must provide proof of a minimum of two (2) years of experience in lift station operations and maintenance to include pump and electrical experience. The contractor must have access to equipment to pull and service pumps as well pumping and hauling lift station waste. The contractor must be able to have a twenty-four (24) hour seven (7) days a week response time and be able to respond to site within two hours after notification of spill or overflow.
- 2) Provide twenty-four (24) hour emergency telephone numbers, enabling the City of Orlando to notify the property owner and contractor of reported emergency.
- 3) Upon expiration or change of status of the contractor, the Office of Environmental Control shall be notified within 72 hours.
- 4) A sign posted on or adjacent to the lift station site (preferably on the control panel). The sign size should be approximately 24" x 30", white background with red letters. The letters should be of a size legible from a distance of 30 feet. The sign shall state the following:
  - a. Private Sanitary Sewer Lift Station
  - b. In case of Emergency call.....
  - c. Owner or Business Name and phone number
  - d. Contractors name and phone number  
(See attachment on sign design)
- 5) The City shall have the right to inspect all private wastewater collection systems and appurtenances, and to cause discontinuance of sewer service if the private wastewater collection system is not maintained in a sanitary and effective operating condition or if the public sewer facilities may be harmed thereby